

## Results of Test: BMT/MTP/F14266/B/01/02/03

### Portrisa S.A

Ponte da Pedra  
2415 - 926  
Leiria - Portugal

This document confirms that performance testing was conducted from 31 October 2014 to 27 November 2014. Testing was conducted to Class 3N according to BS EN 1627: 2011 Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglary resistance - Requirements and classification, following test methods:

- BS EN 1628: 2011 Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglary resistance - Test Method for the determination of resistance under static load
- BS EN 1629: 2011 Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglary resistance - Test Method for the determination of resistance under dynamic load
- BS EN 1630: 2011 Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglary resistance - Test Method for the determination of resistance to manual burglary attempts.


The following results were achieved:

| Product tested                      | START/MAX Single leaf doorset (inward opening) |
|-------------------------------------|------------------------------------------------|
| Test Identification                 | Classification according to EN 1627            |
| EN 1628 Mechanical static load test | Class 3* / Class 3N**                          |
| EN 1629 Impact dynamic load test    | Class 3* / Class 3N**                          |
| EN 1630 Manual attack               | Class 3* / Class 3N**                          |

The results relate only to the specimens tested, as detailed in the technical specification



Issued by:  
James Bacchus - Technical Officer



Authorised by:  
Kyle Morris - Senior Technical Officer  
Issue date: 22<sup>nd</sup> September 2015

#### BM TRADA

Chiltern House, Stocking Lane, Hughenden Valley, High Wycombe, HP14 4ND, UK

Tel: 01494 569800 Fax: 01494 564895

Web: [www.bmtradagroup.com](http://www.bmtradagroup.com) Email: [testing@bmtrada.com](mailto:testing@bmtrada.com)

This document is confidential and remains the property of Chiltern International Fire Ltd, trading as BM TRADA



1762